

Annual Drinking Water Quality Report
POSEY TOWNSHIP WATER CORPORATION
PWS ID #5288006

Dear Customer:

Please find enclosed this year's Annual Water Quality Report. This report is designed to inform you about the quality water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. Our water sources are drilled wells located south of Hardinsburg and a connection to Patoka Lake Regional Water & Sewer District south of Paoli on S.R. 37 and another connection on Valeene Road.

We are pleased to report that our drinking water meets federal and state requirements. The 2019 testing included monthly bacteriological tests (4 collected monthly), of which none tested positive for Total Coliform. During 2019 testing was required for Trihalomethanes (TTHM), and Haloacetic Acid (HAA5), Nitrate and Radioactive Contaminants. Lead & Copper testing was also conducted again in 2019. We received a violation due to not testing the required number of sites during 2018, therefore testing of the correct number of samples was conducted in 2019. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated. We had no MCL, LRAA Violations of Haloacetic Acids (HAA5.) If you have any questions about this report or concerning your water utility, please feel free to contact our General Manger, Jody Wiseman. Board Meetings are held monthly on the 3rd Monday evening of each Month at 7:00 p.m., local time, at our office in Hardinsburg.

Posey Township Water Corporation routinely monitors for constituents in your drinking water according to Federal and State laws. This report shows the results of our monitoring for the period of January 1st to December 31st, 2019. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA and CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline at (800)426-4791.

The sources of drinking water (both tap water and bottled water) include river, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally—occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

- ◆ Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems ,agricultural livestock operations, and wildlife.
- ◆ Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- ◆ Pesticides and herbicides, which may come from a variety of sources such as agriculture, storm water runoff, and residential uses.
- ◆ Organic chemicals, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- ◆ Radioactive materials, which can be naturally-occurring or be the result of oil and gas production and mining activities.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women or young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead> or the Safe Drinking Water Hotline.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottles water which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800)426-4791.

Also included in this mailing are Water Quality Results from Patoka Lake Regional Water & Sewer District as nearly all of the water supplied is now from the Patoka Lake R. W. S. D. source.

We at Posey Township Water Corporation work to provide quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

Thank you for your continued understanding.

POSEY TOWNSHIP WATER CORPORATION
 CONSUMER CONFIDENCE REPORT
 JULY 2020
 REPORTING TEST RESULTS FOR 2019
 SAMPLES COLLECTED FROM WELL FIELD CONTROL BUILDING
 SOURCE: GROUND/WELL WATER

Definitions:

IDEM = Indiana Department of Environmental Management
 EPA = Environmental Protection Agency
 < = Less than the number shown to the left
 MCL = Maximum Contaminant Level-The highest level of a contaminant that is allowed in drinking water. MCL's are set as close as possible to MCLG's as feasible using the best available treatment technology.
 MCLG = Maximum Contaminant Level Goal - The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLG's allow for a margin of safety.
 DL = Detectable Limit
 ppm = parts per million or milligrams per liter
 AL = Action Level - The concentration of a contaminant, which, if exceeded, trigger treatment or other requirements that water systems must follow.
 U.C. = Unregulated Contaminates
 ug/L = Parts per billion

SYNTHETIC ORGANIC COMPOUNDS - 2018

	DL ug/L	Result ug/L		DL ug/L	Result ug/L
REGULATED					
Alachlor (Lasso)	0.1	BDL	Hexachlorocyclopentadiene	0.1	BDL
Atrazine	0.1	BDL	Lindane	0.02	BDL
Benzo(a)pyrene	0.02	BDL	Methoxychlor	0.1	BDL
Carbofuran	0.9	BDL	Oxamyl (Vydate)	1.0	BDL
Chlordane (alpha & gamma)	0.1	BDL	Pentachlorophenol	0.04	BDL
2,4-D	0.1	BDL	Picloram (Tordon)	0.1	BDL
Dalapon	1.0	BDL	PCBs	0.5	BDL
DBCP	0.01	BDL	Simazine	0.07	BDL
Dinoseb	0.1	BDL	2,3,4-TP (Silvex)	0.1	BDL
Dequat	0.4	BDL	Toxapene	1.0	BDL
Di(2-ethylexyl)adlpate	0.6	BDL			
Di(2-ethylexyl)phthaiate	0.6	BDL			
Endothall	9.0	BDL			
Endrin	0.01	BDL			
Ethylene Dibromide (EDB)	10.0	BDL			
Heptachlor	0.04	BDL			
Heptachlor Epoxide	0.02	BDL			
Hexachlorobenzene	0.1	BDL			

RADIOACTIVE CONTAMINANTS - 2019

	MCL	Result		MCL	Result
Gross Alpha	15	1.6+2.7			pCi/L
Radium-228		0.07+0.33			pCi/L

	Det. Level	Result (mg/L)	MCL (mg/L)	2019	MCLG	(AL)	90TH PERC.	UNITS
Nitrate	0.1	BDL	10.0	Copper	1.3	1.3	0.23	ppm
				Lead	0	15	5.2	ppb

Disinfection Process Byproducts

2019	UNIT	MCL	RANGE	SOURCE
Haloacetic Acids 5	ug/L	60	25-44	By-product for drinking water disinfection
Total Trihalomethanes	ug/L	80	24.5-68	By-product for drinking water disinfection

2017		
Barium	0.034	0.034
Fluoride (Adj.)	1.3	1.3

Patoka Lake Regional Water District

WATER QUALITY DATA 2019

Inorganic Contaminants(2019)

	MCL	D.L.	RESULT
	ug/L	ug/L	ug/L
Antimony	6	1	BDL
Arsenic	10	1	BDL
Barium	2000	2	27
Beryllium	4	0.3	BDL
Cadmium	5	1	BDL
Chromium	100	0.9	BDL
Cyanide, Total	0.2	0.02	BDLmg/L
Fluoride	4	0.1	.9mg/L
Mercury	2	0.1	BDL
Nickel	100	1	BDL
Nitrate	10	0.1	BDL
Selenium	50	2	BDL
Sodium	No MCL	0.1	2.4mg/L
Thallium	2	0.3	BDL
Nitrite	1		

Definitions

"MCL"	means maximum contaminant level
"BDL"	means below detectable limit
"pCi/L"	means picocuries per liter
"D.L."	means detectable limit
2012 "mg/L"	means part per million or milligrams per liter
"NTU"	means nephelometric turbidity unit
"ug/L"	means part per billion or micrograms per liter
"U.C."	means unregulated contaminates

Radioactive Contaminants(2018)

	MCL	RESULT	
Uranium	2016 20.1	.01+0.00	pCi/L
Radium-226	2016	.14 + .08	pCi/L
Radium-228	2017	.61 + 0.51	pCi/L
Gross Alpha	2017 15	0.99 + 0.69	pCi/L

Volatile Organic Contaminants(2019)

	MCL	D.L.	RESULT
	ug/L	ug/L	ug/L
Benzene	5	0.5	BDL
Carbon Tetrachloride	5	0.5	BDL
Chlorobenzene	100	0.5	BDL
1,2-Dichlorobenzene	600	0.5	BDL
1,4-Dichlorobenzene	75	0.5	BDL
1,2-Dichloroethane	5	0.5	BDL
1,1-Dichloroethylene	7	0.5	BDL
1,2 Dichloroethylene, cis	70	0.5	BDL
1,2-Dichloroethylene, trans	100	0.5	BDL
Dichloromethane	5	0.5	BDL
1,2-Dichloropropane	5	0.5	BDL
Ethylbenzene	700	0.5	BDL
Styrene	100	0.5	BDL
Tetrachloroethylene	5	0.5	BDL
Toluene	1000	0.5	BDL
1,2,4-Trichlorobenzene	70	0.5	BDL
1,1,1-Trichloroethane	200	0.5	BDL
1,1,2-Trichloroethane	5	0.5	BDL
Trichloroethylene	5	0.5	BDL
Vinyl Chloride	2	0.2	BDL
Total Xylenes	10000	0.5	BDL
Methy-T-butyl ether		0.5	BDL
TOTAL TRIHALOMETHANES	80	0.5	56.5
Bromodichloromethane		0.5	5.5
Bromoform		0.5	BDL
Chlorodibromomethane		0.5	BDL
Chloroform		0.5	51

	MCL	RESULT	
	ug/L	ug/L	
Haloacetic Acids 5 (4)	60	35.8 Average	
	2019	Range	25 45
Total Trihalomethanes(4)	80	41.4 Average	
	2019	Range	22.3 69

	MCL	RESULT
	mg/L	mg/L
Lead 90th percentile	2017 0.015	0.005
Copper 90th percentile	2017 1.3	0.24

Total Organic Carbon (TOC)

	MCL	Range	20.00%	To 42%
Percent Removal TOC	25%	Average<25%	32.0%	

Highest Turbidity Measurement 2019

.22 3-18th 2019